




Fresh Water




Cleaning process



Existing floor drain  
(divide into **short** sections)



New (small) sump  
~2kL



pH

EC


Controller

Water meets  
quality requirement

Water does not  
meet quality  
requirement



Treatment




Recycled  
Water  
Storage Tank


Fresh water  
in case of low  
level trigger



Overflow to  
main sump  
in case of  
high level  
trigger



Recycled  
Water  
Distribution



Main Sump



To WWT